

DIVISION 26 – ELECTRICAL

SECTION 26 53 00 – EXIT SIGNS

PART 1: GENERAL

1.01 Scope of Standards

- A. This standard provides general guidance concerning the specific preferences of Texas State University-San Marcos for Exit Signs.
- B. Texas State University-San Marcos recognizes that project conditions and requirements vary, thus precluding the absolute adherence to the items identified herein in all cases. However, unless there is adequate written justification, it is expected that these guidelines will govern the design and specifications for Texas State University-San Marcos projects.

1.02 General

- A. All emergency exit signs shall be LED type. Where possible, exit sign shall be wall mounted directly above the exit door. In this configuration, the exit sign shall be mounted with back to wall. In addition, exit signs shall comply with the following:
 - 1. The exit sign configuration shall be determined based on code requirements for exit paths. Configuration considerations include number of faces and direction of chevron/arrows showing path to exit.
 - 2. In spaces designated by the University as upgraded interiors, exit signs shall be acrylic edge lit type.

PART 2: PRODUCTS

- A. Preferred Exit Light is Lithonia Quantum Style #LQM-S-W-3-R-120/277-ELN-FA.
- B. During a Power Outage, exit light should flash and have audible intermittent alert.

PART 3: EXECUTION (NOT USED)

END OF SECTION 26 53 00