

DIVISION 26 - ELECTRICAL

SECTION 26 56 17 – PARKING GARAGE BAY LIGHTING

PART 1: GENERAL

1.01 Scope of Standards

- A. This standard provides general guidance concerning the specific preferences of Texas State University for Parking Garage Bay Lighting.
- B. Texas State University recognizes that project conditions and requirements vary, thus precluding the absolute adherence to the items identified herein in all cases. However, unless there is adequate written justification, it is expected that these guidelines will govern the design and specifications for Texas State University projects.

1.02 Design Guidelines

- A. For safety and higher brightness effect, the ceiling structure and beams of each floor of the Parking Garage shall be painted a light color (to be approved by Project Representative).
- B. The illumination levels of Parking Garages shall comply with Section 26 56 00, 1.03.
- C. The lighting controls shall comply with Section 26 50 00, PART 2, D.
 - 1. Lighting fixtures in Parking Garage Bays shall be: LED, Max Light, Down Light.
- D. Project Deliverables shall comply with Section 26 50 00, PART 3, 3.01.

PART 2: PRODUCTS

- A. Approved fixtures:
 - 1. LED, Max Light, Down Light

PART 3: EXECUTION (NOT USED)

END OF SECTION 26 56 17