

INGRAM SCHOOL OF ENGINEERING

Meet the Team



Luke Scarpato



Lisette Lugo



Lilly Martinez

Project Overview

Goal

Conduct a System Impact Study for integrating a 5 MW solar PV generator into a 24 kV distribution network.

Objective

To study the impacts of interconnecting a 5 MW solar generator to a 24 kV distribution system, focusing on stability, safety, and compliance.

Tools Used

Simulations are performed using Milsoft WindMil to evaluate load flow, short circuit, and flicker levels both before and after PV integration.

Project Requirements

PV Generator

Evaluate impact from PV generation fluctuations to meet flicker standards.

Interconnection

- **Conduct short circuit analysis.**
- 24 kV Distribution System
- Perform load flow and post-integration load flow to detect voltage violations.

Project Objectives

- Analyze the PV generator's effect on the distribution network.
- Maintain voltage stability and avoid overloads or unacceptable flicker levels in the system.
- Ensure the PV generator's integration enhances grid resilience and supports reliable power delivery during varying demand conditions.
- Identify necessary upgrades or mitigations to meet safety and regulatory standards.

$E2.02 - L^3 Energy$

Luke Scarpato, Lisette Lugo, Lilly Martinez **System Impact Study of a 5 MW Photovoltaic Generator** into 24 kV Distribution System

Overall Block Diagrams



Load Flow Analysis



nterconnection requirements guided by IEEE 1547.

Base Case – On Peak – Substation at 120 V

Flicker Analysis

Flick	Flicker Voltage System Wide Pre-Mitigation						
PV Location	Transient Re 0% - 100%	sponse From PV Output	Transient Response 100% - 0% PV Output			123	
Central	0% Output	100% Output	100% Output	0% Output		() 121 ခရ	
Sub Station	Min-Max	Min-Max	Min-Max	Min-Max		01 150	
(V)	Volt LL	Volt LL	Volt LL	Volt LL		119	
120	115.0 - 119.9	114.3 - 119.9	114.4 - 119.9	112.9 - 119.9		118	
125	120.2 - 124.9	119.6 - 124.9	119.6 - 124.8	118.3 - 124.8			
126	121.2 - 124.9	121.5 - 125.9	120.7 - 125.9	119.5 - 125.9		117	

Short Circuit Analysis

Fault Current Analysis						
Location @ Fault	Fault Type	Base Case (A)	Base Case @ 120% (A)	PV Implementation (A)		
North	maxFLL	6767.3	8120.8	6877.1		
North	maxFLG	5104.3	6125.2	5263.5		
Central	maxFLL	8710.9	10453.1	8854.0		
Central	maxFLG	15088.6	18106.3	15269.0		
South	maxFLL	6443.6	7732.3	6561.9		
South	maxFLG	7031.1	8437.3	7169.5		
 All protective devices should be upgraded to ensure proper coordination and safe operation, with breakers sized according to IEEE C37.010 and IEEE C37.13, fuses and reclosers rated per IEEE C37.46 and IEEE C37.60, and 						











Post Mitigation

Acknowledgements

Faculty Advisor: Dr. Billy Diong Sponsor: TRC