2024 Annual Drinking Water Quality Report Texas State University - San Marcos January 1st - December 31st, 2024

This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water. For more information regarding this report contact <u>Carl Teague at 512-245-8629</u>. Este reporte incluye información importante sobre el agua para toma. Para assistencia en español, favor de llamar al telefono 512-245-1985.

TEXAS STATE

PWS I.D. TX1050003



This report is a summary of the quality of the water we provide our customers. The analysis was made by using the data from the most recent U.S. Environmental Protection Agency (EPA) required tests and is presented in the attached pages. We hope this information helps you become more knowledgeable about what's in your drinking water.

Facts About Your Water Sources

SPARING AND

A Source Water Susceptibility Assessment for your drinking water source(s) has been conducted by the Texas Commission on Environmental Quality and results indicate that some of your sources are susceptible to certain contaminants. The sampling requirements for your water system are based on this susceptibility and previous sample data. Any detections of these contaminants may be found in this Consumer Confident Report. The report describes the susceptibility and the types of constituents that may encounter your drinking water source based on human activities and natural conditions. The information contained in this assessment allows us to focus our source water protection strategies. Some of this source water assessment information will be available later this year on Texas Drinking Water Watch at http://dww.tceq.state.tx.us/DWW/. For more information on source water assessments and protection efforts at our system, please contact us.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791. To ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants (such as calcium, sodium, or iron) may be found in drinking water that may cause taste, color or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact us.

> Lyndon Baines Johnson Class of 1930

Facts (Continued)

Contaminants that may be present in source water before treatment include:

The Alter Att

- Microbial contaminants such as viruses and bacteria which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- Inorganic contaminants such as salts and metals which can be naturally occurring or come from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production and can also come from gas stations, urban storm water runoff and septic systems.
- Radioactive contaminants which can be naturally occurring or the result of oil and gas production and mining activities.

Special Notice

You may be more vulnerable than the general population to certain microbial contaminants, such as Cryptosporidium, in drinking water. Infants, some elderly, or immunocompromised persons such as those undergoing chemotherapy for cancer; persons who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders, can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. Additional guidelines on appropriate means to lessen the risk of infection by Cryptosporidium are available from the <u>Safe Drinking Water Hotline at (800) 426-4791.</u>

Information About Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water primarily comes from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at http://www.epa.gov/safewater/lead.

Service Line Inventory

Texas State University has made available a recently developed service line inventory. To access this inventory, please visit <u>https://www.facilities.txst.edu/utilities/drinking-water.html</u> and or contact <u>Carl Teague at 512-245-8629</u>

Key Terms & Abbreviations

- <u>AL: (Action Level):</u> The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
- <u>Avg:</u> Regulatory compliance with some MCLs is based on running annual average of monthly samples.
- <u>Level 1 Assessment:</u> A study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.
- <u>Level 2 Assessment:</u> A detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.
- <u>MCL (Maximum Contaminant Level)</u>: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- <u>MCLG (Maximum Contaminant Level</u> <u>Goal)</u>: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- MRDL (Maximum Residual Disinfectant Level): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

- <u>MRDLG (Maximum Residual Disinfectant</u> <u>Level Goal)</u>: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- <u>N/A:</u> Not applicable
- <u>NTU: (Nephelometric Turbidity Units):</u> Measurement of the clarity, or turbidity, of water. Turbidity more than 5 NTU is just noticeable to the average person.
- <u>pCi/L</u>: Picocuries per liter (a measure of radioactivity)
- <u>ppq (parts per quadrillion, or picogram per</u> <u>liter):</u> One ounce in 7,350,000,000,000 gallons of water, or 1 penny in 10 trillion dollars.
- <u>ppt (parts per trillion, or nanograms per</u> <u>liter):</u> One ounce in 7,350,000,000 gallons of water, or 1 penny in 10 billion dollars.
- <u>ppb (parts per billion or micrograms per liter)</u>: One ounce in 7,350,000 gallons of water, or 1 penny in 10 million dollars.
- <u>ppm (parts per million or milligrams per</u> <u>liter):</u> One ounce in 7,350 gallons of water, or 1 penny in 10 thousand dollars.
- <u>Treatment Technique:</u> A required process intended to reduce the level of a contaminant in drinking water.

Public Participation Opportunities Date: None Scheduled Time: None Scheduled Location: None Scheduled Organic Contaminants: Not evaluated, or none detected.

Maximum Residual Disinfectant Level: Systems must complete and submit disinfection data on the Disinfection Level Quarterly Operating Report (DLQOR). On the CCR report, the system must provide disinfectant type minimum, maximum and average levels.

<u>Year</u>	<u>Disinfectant</u>	<u>Average</u> <u>Level</u>	<u>Minimum</u> <u>Level</u>	<u>Maximum Level</u>	<u>MCL</u>	<u>MCLG</u>	<u>Unit of</u> <u>Measure</u>	Source of Disinfectant
2024	Chlorine Residual, Free	.92	.5	1.4	4	4	ррт	Disinfectant used to control microbes.

<u>Unregulated Initial Distribution System Evaluation for Disinfection Byproducts:</u> Waived or not yet sampled.

Unregulated Contaminants: Not reported or none detected.

				Lead & Cop	per			
<u>Year</u>	<u>Contaminant</u>	<u>MCGL</u>	<u>Action</u> <u>Level</u>	<u>90th Percentile</u>	<u># sites Over AL</u>	<u>Unit of</u> <u>Measure</u>	<u>Violation</u>	<u>Likely Source of</u> <u>Contamination</u>
2023	Copper	1.3	1.3	1.061	1	ppm	N	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems
2023	Lead	0	15	1.3	0	ppb	N	Corrosion of household plumbing systems; Erosion of natural deposits

lated Contention and

				Keg	ulated Conta	aminants			
Maximum ContaminantTot: MLevel GoalCo		<u>Total Coliform</u> <u>Maximum</u> <u>Contaminant</u> <u>Level</u>		<u>Highest No. of</u> <u>Positive</u>	<u>Fecal Coliform</u> <u>or E. Coli</u> <u>Maximum</u> <u>Contaminant</u> <u>Level</u>	<u>Total No. of Positive E. Coli</u> or Fecal Coliform Samples		<u>Violation</u>	<u>Likely Source of</u> <u>Contamination</u>
0 5% of N Samp Pos		Ionthly les are itive	2	1 Fecal or 1 Routine and 1 Repeat Positive	1		Ν	Naturally Present in the environment	
<u>Contaminants,</u> <u>Disinfectants and</u> <u>Disinfection By-</u> <u>Products</u>	nants, nts and on By- ucts		<u>Highes</u> Level Detecte	t <u>Range of</u> <u>Level</u> d <u>Detected</u>	<u>Maximum</u> <u>Contaminant</u> <u>Level Goal</u>	<u>Maximum</u> <u>Contaminant</u> <u>Units</u> <u>Level</u>		<u>Violation</u>	<u>Likely Source of</u> <u>Contamination</u>
Total Trihalomethanes (TTHM)	2024		15.2	2.6-15.2	No goal for the total	80 ppb		N	By-product of drinking water disinfection
Halo acetic Acid (HAA5)	2024		2024 2.0		No goal for the total	60 ppb		Ν	By-product of drinking water disinfection
<u>Inorganic</u> <u>Contaminants</u>	Collection Date		<u>Highes</u> <u>Level</u> <u>Detecte</u>	t <u>Range of</u> <u>Level</u> d <u>Detected</u>	<u>Maximum</u> <u>Contaminant</u> Level Goal	<u>Maximum</u> <u>Contaminant</u> <u>Level</u>	<u>Units</u>	<u>Violation</u>	<u>Likely Source of</u> <u>Contamination</u>
Barium	n 2022		0.0396	0.0396- 0.0396	2	2	ppm	N	Discharge of drilling waste; Discharge from metal refineries: Erosion from natural deposits
Fluoride 2023		2023 .19		.1919	4	4.0	ррт	N	Erosion from natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Nitrate [measured as Nitrogen]	20	024	1.83	1.83-1.83	10	10	ррт	N	Runoff from fertilizer use; Leaching from septic tanks; sewage; Erosion from natural deposits
<u>Radioactive</u> <u>Contaminants</u>	<u>Collect</u>	ion Date	Highes Level Detecte	t <u>Range of</u> <u>Level</u> d <u>Detected</u>	<u>Maximum</u> <u>Contaminant</u> <u>Level Goal</u>	<u>Maximum</u> <u>Contaminant</u> <u>Level</u>	<u>Units</u>	<u>Violation</u>	Likely Source Of Contamination
Gross Alpha Compliance	7-:	5-23	4	< 3 - 4	0	15	pCi/L		Erosion from natural deposits

<u>Violations Table</u>										
Lead and Copper Rule										
The Lead and Copper Rule protects public health by minimizing lead and copper levels in drinking water, primarily by reducing water corrosivity. Lead and copper enter drinking water mainly from corrosion of lead and copper containing plumbing materials.										
Violation Type	<u>Violation</u>	<u>Begin</u>	<u>Violati</u>	<u>on End</u>	<u>Violation Explanation</u>					
	A HULL		Rev	ised Total Colif	orm Rule (RTCR)					
The Revised To water may be nat	otal Coliform Rule contaminated wit 1sea, headaches, o	e (RTCR) see th human or or other symj	eks to prevent w animal waste. I otoms. They ma	vaterborne dise Human pathoge Ny pose a greate	ases caused by E. coli. E. coli are bacteria whose presence indicates that the ens in these wastes can cause short-term effects, such as diarrhea, cramps, er health risk for infants, young children, pregnant and elderly.					
Violation Type	<u>Violation</u>	<u>Begin</u>	<u>Violati</u>	<u>on End</u>		<u>v</u>	<u>iolation Explanation</u>			
Q										
N. A.	ROW AT			Public Notifi	ication Rule		MUS KARNA MARY MARKS			
The Public Notification Rule helps to ensure that consumers will always know if there is a problem with their drinking water. These notices immediately alert consumers if there is a serious problem with their drinking water (e.g., a boil water emergency).										
Violation Type	Violation Type Violation Begin Violation End Violation End									
BWNP-BWN	3-24-24 3-27-24 Low Distribution Pressure, Line Break									
	1. 1911		Secondary (No	and Other Not associated advo	Regulated Constituerse health effects)	<u>ients</u>				
<u>Year or Range</u>	<u>Constituent</u>	<u>Average</u> <u>Level</u>	<u>Minimum</u> <u>Level</u>	<u>Maximum</u> <u>Level</u>	<u>Secondary Limit</u>	<u>Unit Of</u> <u>Measure</u>	Source of Constituent			
2011-2023	Bicarbonate	317.5	267	368	NA	ррт	Corrosion of carbonate rocks such as limestone.			
2024	Calcium	94.5	89	100	NA	ppm	Abundant naturally occurring element.			
2024	Chloride	27.5	25	30	300	ppm	Abundant naturally occurring element; used in water purification; byproduct of oil field activity.			
2011-2023	Copper	0.998	0.148	1.848	NA	ppm	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives.			
2024	Iron	.0405	.01	.071	10	ppm	Corrosion of household plumbing systems; erosion of natural deposits			
2011-2023	Magnesium	17.1	15.6	18.6	NA	ррт	Abundant naturally occurring element.			
2024	Manganese	0.022	0.013	0.031	0.3	ррт	Abundant naturally occurring element			
2011-2023	Nickel	0.0026	0.002	0.0032	NA	ррт	Erosion of natural deposits.			
2024	рН	7.5	7.0	8.0	>7.0	units	Measure of corrosively of water.			
2024	Sodium	21	19	23	NA	ррт	Erosion of natural deposits; byproduct of oil field activity.			
2024	Sulfate	27	17	37	300	ррт	Naturally occurring; common industrial byproduct; byproduct of oil field activity.			
2024	Total Alkalinity as CaCO3	278	262	294	NA	ррт	Naturally occurring soluble mineral salts.			
2024	Total Dissolved Solids	390	348	432	1000	ррт	Total dissolved mineral constituents in water.			
2024	Total Hardness as CaCO3	358	297	419	NA	ррт	Naturally occurring calcium.			
2002-2023	Zinc	0.0046	0.004	0.0052	5	ppm	Moderately abundant naturally occurring element used in the metal industry.			